UL Product iQ™

VSQV.EX28409 - Fire Department Connections

Fire Department Connections

See General Information for Fire Department Connections

HACI AYVAZ ENDUSTRIYEL MAMULLER SAN VE TIC A.S. EX28409
Hadimkoy Mahallesi
Mustafa Inan Caddesi No:44 Arvavutkoy
34555 istanbul, TURKEY
Exposed Type.

Model	Pattern	Size (in.)	Rated Pressure (psig)
AFDC-100	Straightway	2-1/2 by 2-1/2 by 4	300

Marking: Trademark and/or Tradename AYVAZ

Last Updated on 2020-06-26

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"