CERTIFICATE OF CONSTANCY OF PERFORMANCE

2809-CPR-F0087

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Model H Wet Alarm Valves

Sizes: 3, 4, 6 and 8 in. NPS
(DN80, DN100, DN150, and DN200)
Vertical Installation
Rated Working Pressure 3, 4 and 6 in. NPS 1720 kPa (250 psi)
Rated Working Pressure 8 in. NPS 1375 kPa (200 psi)

placed on the market under the name or trade mark of

HD Fire Protect Limited
D-6/2, Road No. 34,
Wagle Industrial Estate,
Thane
Maharashtra
400604
India

and produced in the manufacturing plant

HD Fire Protect Limited
K-98 Ajanta Road
Jalagon
Maharashtra
425 003
India

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 12259-2:1999 including Amendments A1:2001, A2:2005 and Corrigendum No. 1

under system 1 for the performances set out in this certificate (see Examination Report PR463900 dated 15 October 2025) are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 16 October 2025 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issue 1 , Dublin, dated 16 October 2025

Richard Zammitt, Certification Manager
On behalf of FM Approvals Europe Limited
(PR463900)

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin, Ireland D02 E440
E-mail: cpr@fmapprovals.com Web: www.fmapprovals.com

This certificate remains the property of FM Approvals and has been issued in accordance with FM Approvals CPR Certification Scheme.