Certificate of Compliance

This certificate is issued for the following:

Alarm Check Valves
Model H
(see attached sheet)

Prepared for:

HD Fire Protect Pvt. Ltd.
K-98, Ajanta Road
Jalagon - 425 003, India

Manufactured at:

HD Fire Protect Pvt. Ltd.
K-98, Ajanta Road
Jalagon - 425 003, India

FM Approvals Class: 1041, dated February 2006

Approval Identification: 0003047475 Approval Granted: October 4, 2013

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

Member of the FM Global Group

Certificate of Compliance

Models H

Product Designation	*Description*	*Nominal Pipe Size, in. (mm)*	*Max Working Pressure, psi (kPa)*	*Remarks*
Model H	Alarm Check Valve, Flanged Ends	3, 4, 6 (80, 100, 150)	250 (1725)	a, b, c
Model H	Alarm Check Valve, Flanged Ends	8 (200)	200 (1380)	a, b, c
Model H	Alarm Check Valve, Grooved Ends	3, 4, 6 (80, 100, 150)	250 (1725)	a, b, c
Model H	Alarm Check Valve, Grooved Ends	8 (200)	200 (1380)	a, b, c
Model H	Alarm Check Valve, Flanged x Grooved Ends	3, 4, 6 (80, 100, 150)	250 (1725)	a, b, c
Model H	Alarm Check Valve, Flanged x Grooved Ends	8 (200)	200 (1380)	a, b, c

a. Resilient seat.
b. With Model RC9 retard chamber.
c. Vertical installation only.

FM Approvals®

Member of the FM Global Group