Certificate of Compliance

Certificate Number:

EX3971

Report Reference:

EX3971-20030507

Issue Date:

2025-05-29

Issued to:

Please see the Addendum for Manufacturing Location Information

TORNATECH INC
4100 Desserte Sud, (A-440 Ouest)
Laval
QC
CA
H7T 0H3

This certificate confirms that representative samples of:
PUMP CONTROLLERS, FIRE
USL, CNL - Model GPD Series controller for engine-driven centrifugal fire pumps.
Has been evaluated by UL LLC in accordance with Standard(s) for Safety:
Please See the Addendum for Standards of Safety
Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2023 UL LLC. All rights reserved.

Certificate of Compliance

Certificate Number: EX3971
Report Reference: EX3971-20030507
Issue Date: 2025-05-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum:

Manufacturing Locations for File EX3971:

TORNATECH INC
4100 Desserte Sud, (A-440 Ouest)
Laval
QC
CA
H7T 0H3

Tornatech Europe SA
Rue des Sablières numéro 45
Unité 68
Mont-Saint-Guibert
BE
1435

TORNATECH FZE
PO Box 18435
Plot No S10131, Jebel Ali South
Dubai
AE

Standards for Safety:

UL 218 / CSA C22.2 No. 263-15, Fire Pump Controllers, 3rd / 2nd Edition
UL 508, Industrial Control Equipment, Edition 19
NFPA 20, Standard for the Installation of Stationary Pumps for Fire Protection

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2023 UL LLC. All rights reserved.