ONLINE CERTIFICATIONS DIRECTORY

VPLX.EX659
Valves, Alarm

Page Bottom

Valves, Alarm

See General Information for Valves, Alarm

VIKING CORP EX659
210 N INDUSTRIAL PARK RD
HASTINGS, MI 49058 USA

Model J-1, 3, 4, 6, 8 inch. sizes rated for 300 psig.

Model J-1 4, 6 and 8 inch. sizes rated for 175 psig, for use with Refrigerated Area / Cold Storage Trim.

Model J-1 valve provided with Model C-1 retarding chamber.

Model F-2 water motor gong.

Last Updated on 2011-11-16

Questions? Print this page Notice of Disclaimer Page Top

Copyright © 2011 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.



ONLINE CERTIFICATIONS DIRECTORY

VPLX7.EX659
Valves, Alarm Certified for Canada

Page Bottom

Valves, Alarm Certified for Canada

See General Information for Valves, Alarm Certified for Canada

VIKING CORP EX659
210 N INDUSTRIAL PARK RD
HASTINGS, MI 49058 USA

Model J-1, 3, 4, 6, 8 in. sizes rated for 300 psig.

J-1 valves provided with Model C-1 retarding chamber.

Model F-2 water motor gong.

Last Updated on 2011-11-16

Questions? Print this page Notice of Disclaimer Page Top

Copyright © 2011 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

